



VKAN CERTIFICATION & TESTING CO., LTD.

No. 3,Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, 510663, P. R. China
Tel.: +86-20-32293888 Fax: +86-20-32293889 E-mail: office@cvc.org.cn www.cvc.org.cn

GULF-TYPE EXAMINATION CERTIFICATE

Certificate No. 2020GTC8536169411
Date of Issue 2020-01-11
Date of Revision N/A
Date of Expiry 2023-01-11

Applicant AVE S.P.A.
Via Mazzini 75 25086 Rezzato Brescia Italy

Manufacturer AVE S.P.A.
Via Mazzini 75 25086 Rezzato Brescia Italy

Manufacturing Location Wenzhou Daguan Electrics Co., Ltd.
Dongmeng Industrial Zone, Wuniu Town, Yongjia County, Wenzhou, Zhejiang, China

Country of Origin China

Product Name Flush-type 13A Switched socket-outlet with Earthing-contact and shutter with/without indicator lamp

Trade Mark bsave

Model No. BSN21097/2PN BSN11097/2PN BSN11097/1PN BSN21097/2P BSN21097/1P BSN11097/2P
BSN11097/1P

File Reference No. 2019G8536217711

Standards Applied BS 1363-2:2016+A1:2018

GSO Countries Considered United Arab Emirates, Kingdom of Saudi Arabia, Kingdom of Bahrain, Sultanate of Oman, Republic of Yemen,
State of Kuwait, State of Qatar

Conclusion

The tested sample meets the requirements of the above mentioned standards and hence fulfils the requirements of *Gulf Technical Regulation for Low Voltage Electrical Equipment and Appliances (BD-142004-01)-Annex (4) & Annex (1)*. The results only relate to the items tested.

This certificate is only valid for the product and configuration described, in conjunction with the test data detailed in the related test reports and photos attached on the following pages.


In case of an amendment of the applicable standards, requirements and modification of the products, the Applicant/Manufacturer shall apply for updating of the certificate accordingly to maintain the validity of the certificate.



Authorized Person:

Signature:

Official Stamp:





VKAN CERTIFICATION & TESTING CO., LTD.

No. 3,Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, 510663, P. R. China
Tel.: +86-20-32293888 Fax: +86-20-32293889 E-mail: office@cvc.org.cn www.cvc.org.cn

GULF-TYPE EXAMINATION CERTIFICATE

Certificate No. 2020GTC8536169411

Date of Issue 2020-01-11

Date of Revision N/A

Date of Expiry 2023-01-11

Product Specifications:

Electrical Ratings 13A 250V~

Product Dimensions BSN21097/2PN, BSN21097/2P, BSN21097/1P: L146mm×W86mm;
BSN11097/2PN, BSN11097/1PN, BSN11097/2P, BSN11097/1P: L86mm×W86mm

Test Report No. GT0012019-0593

Report Issue Date 2019-12-18

Differences Descriptions of the Models (if any) BSN21097/2PN: two-gang, Double-pole switch, with Indicator lamp; BSN11097/2PN: one-gang, Double-pole switch, with Indicator lamp;BSN11097/1PN: one-gang, Single-pole switch, with Indicator lamp;BSN21097/2P: two-gang, Double-pole switch; BSN21097/1P: two-gang, Single-pole switch; BSN11097/2P: one-gang, Double-pole switch; BSN11097/1P: one-gang, Single-pole switch

Remark Only models with double-pole switch are exported to the kingdom of Saudi Arabia.

Product Photos:

Product Marking for Representative Model BSN21097/2PN



Authorized Person:

Signature: *Xie*

Official Stamp:



This page is an indispensable part of the Certificate and may not be used separately.



VKAN CERTIFICATION & TESTING CO., LTD.

No. 3,Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, 510663, P. R. China
Tel.: +86-20-32293888 Fax: +86-20-32293889 E-mail: office@cvc.org.cn www.cvc.org.cn

GULF-TYPE EXAMINATION CERTIFICATE

Certificate No. 2020GTC8536169411
Date of Issue 2020-01-11
Date of Revision N/A
Date of Expiry 2023-01-11

Product Photos:

Model BSN11097/1P		Model BSN11097/1PN		Model BSN11097/2P	
Model BSN11097/2PN		Model BSN21097/1P		Model BSN21097/2P	
Model BSN21097/2PN		/			



Authorized Person:

Signature: *Xie Hong*

Official Stamp:



This page is an indispensable part of the Certificate and may not be used separately.



VKAN CERTIFICATION & TESTING CO., LTD.

No. 3,Tiantaiyi Road, Kaitai Avenue, Science City, Guangzhou, 510663, P. R. China
Tel.: +86-20-32293888 Fax: +86-20-32293889 E-mail: office@cvc.org.cn www.cvc.org.cn

GULF-TYPE EXAMINATION CERTIFICATE

Certificate No. 2020GTC8536169411
Date of Issue 2020-01-11
Date of Revision N/A
Date of Expiry 2023-01-11

More details

Product Name	Model	Number of outlets	Faceplate size (LxW)	Indicator lamp	The switch	GSO Countries Considered
Flush-type 13A Switched socket-outlet with Earthing-contact and shutter with indicator lamp	BSN21097/2PN	2	146mmx86mm	With	Double-pole	AE,BH,OM,YE,KW,QA,SA
	BSN11097/2PN	1	86mmx86mm	With	Double-pole	
Flush-type 13A Switched socket-outlet with Earthing-contact and shutter	BSN21097/2P	2	146mmx86mm	Without	Double-pole	
	BSN11097/2P	1	86mmx86mm	Without	Double-pole	
Below models are not applicable for Kingdom of Saudi Arabia						
Flush-type 13A Switched socket-outlet with Earthing-contact and shutter	BSN11097/1P	1	86mmx86mm	Without	Single-pole	AE,BH,OM,YE,KW,QA
	BSN21097/1P	2	146mmx86mm	Without	Single-pole	
Flush-type 13A Switched socket-outlet with Earthing-contact and shutter with indicator lamp	BSN11097/1PN	1	86mmx86mm	With	Single-pole	



Authorized Person:

Signature: *[Handwritten Signature]*

Official Stamp:



This page is an indispensable part of the Certificate and may not be used separately.